


Product	Active Surface Area	Permeate Flow Rate	Salt Rejection	
	Ft2 (m2)	gpd (m3/d)	%	
TMG10	76 (7.1)	1,590 (6.0) or 2385 (9.0)*	99.4	

Test Conditions:

500 ppm NaCl, 100 PSI (1.6 mPa)/*150 (8.3 mPa), 77° F (25°C), ph8.0, 15.0% Recovery Minimum salt rejection is 99.0% Minimum permeate flow is 1320 (5.0)

Dimensions:



A B C D
TMG10 40 (1,016) 1.05 (27) 0.75 (19) 0.3913 (99.4)

Operating Limits:

Membrane Type Cross Linke	ed Fully Aromatic Polamide Composite
Maximum Operating Pressure	365 PSI (4.1 mPa)
Maximum Feed Water Temperature	40°C
Maximum Feed Water Silt Denisty Index	
Free Chlorine Tolerance	<1 ppm
Feed water pH Range, Continuous Operat	ion 3-9
Feed water ph Range, Chemical Cleaning	

Operating Information:

- 1.) For the recommended design range please consult the latest Toray technical bulletin, design guidelines, computer design program, and/or Call TMA and talk with an application specialist. If operating specifications given in this Product Information Bulletin are not strictly followed, the limited warranty will be null and void.
- 2.) All elements are wet tested prior to shipment, storage solution is added and the elements are vacuum bagged in oxygen barrier bags. To prevent biological growth during short term storage, shipment, or system shutdown it is recommended that 'Toray' elements be immersed in a protective solution containing 1% (by weight) sodium metabisulfite (food grade) and permeate.
- 3.) Permeate for the first hour of operation should be discarded.
- 4.) The customer is fully responsible for the effects of chemicals, which are incompatible with the elements. Their use will void the element-limited warranty.

Toray Membranes:

Distriubted By:

Applied Membranes, Inc.

2325 Cousteau Ct. Vista, CA 92083-8346 USA

Phone: (760) 727-3711 Fax: (760) 727-4427

http://www.AppliedMembranes.com Sales@AppliedMembranes.com

Notice: We accept no responsibility for results obtained by the application of this information or the safety or suitability of our products, either alone or in combination with other products. Users are advised to make their own tests to determine the safety and suitability of each product combination for their own purposes.

